



Jacob Sciammas <jacobsciammas@gmail.com>

Inspection of City sewer serving Memorial pool3 messages

Johnson, Mark <Johnsonm@cityoflacrosse.org>

Thu, Feb 16, 2017 at 10:56 AM

To: "Carlyon, Steve" <carlyons@cityoflacrosse.org>

Cc: "Odegaard, Jason" <Odegaardj@cityoflacrosse.org>, "Johnson, Jai" <johnsonj@cityoflacrosse.org>, Jim Webb <JimWebb1224@gmail.com>, "jacobsciammas@gmail.com" <jacobsciammas@gmail.com>

Good morning,

We had our contractor, Flow-Rite, televise the sanitary sewer that serves Memorial Pool Tuesday afternoon, February 14th. The attached drawing shows the scope of the inspection work related to the City's sewer main. Steve Asp and I reviewed the video Wednesday afternoon.

The existing City sewer is a 10" diameter concrete pipe; GIS information indicates a construction date of 1930. The existing pipe had SIGNIFICANT deposits of grease, even after the pipe was cleaned ahead of televising. We will follow-up with UWL to confirm that the kitchen operations that were discharging the grease had been moved to their new student center.

In general the sewer main pipe is in good condition; there are some locations where aggregate is visible which is a common occurrence where concrete pipe was used for a sanitary sewer application. The existing pipe would be a good candidate for future installation of a HDPE lining system but there are no condition issues of concern.

Manholes are of concrete block construction but are also in generally good condition; there were no visible structural defects. These would also be candidates for spray-sealing or some similar in-situ rehabilitation.

All connections from City and UWL facilities come into the northern-most manhole, in kind of a haphazard arrangement. The connection from the Cartwright Center basically points directly at the connection from the pool. It would probably make sense to revise these connections to direct flow into the channel of the manhole.

Steve – You're probably aware that Jay also requested the contractor to televise the private lateral that extends from the pool to northern manhole. Steve Asp dropped-off a copy of the televising video to Jay after the work was completed.

I hope this is useful information. If anyone is interested we can provide a video copy of the inspection of the City's main. Please feel free to contact me with questions, etc. If anyone is interested we can provide a video copy of the inspection of the City's main.

Thank you.

Mark Johnson.

Mark Johnson.
Utilities Office
400 La Crosse Street
La Crosse, WI 54601

Office: [608-789-7588](tel:608-789-7588)
Cell: [608-792-0498](tel:608-792-0498)



Televised section of sanitary sewer-Memorial pool.02152017Capture.PNG
171K

Jacob Sciammas <jacobsciammas@gmail.com> Thu, Feb 16, 2017 at 2:14 PM
To: 7 Barb Janssen <bluffviewhouse@gmail.com>, Joel Dettwiler <joel.dettwiler@gmail.com>, Kate Escher <skescher@gmail.com>

Good data to satisfy fear & speculation.

J

Jacob Sciammas
320 24th St N
La Crosse, WI 54601
[608-519-2518](tel:608-519-2518)

[Quoted text hidden]



Televised section of sanitary sewer-Memorial pool.02152017Capture.PNG
171K

Barb Janssen <bluffviewhouse@gmail.com> Thu, Feb 16, 2017 at 2:19 PM
To: Jacob Sciammas <jacobsciammas@gmail.com>

Excellent!!
[Quoted text hidden]

